


CERTIFICATE

Certificate holder	DIMAS Solar SA 2nd klm Argos-Nafplion 212 00 Argos GREECE
Production facility	Argos
Product	Solar collectors
Type, Model	SOL+ EVO 20, SOL+ EVO 23, SOL+ EVO 25, SOL+ EVO 29 TERRA + EVO 20, TERRA + EVO 23, TERRA + EVO 25, TERRA + EVO 29
Testing basis	DIN EN 12975-1:2011-01 DIN EN 12975-1:2006-06 SOLAR KEYMARK Scheme Rules (2021-07)
Mark of conformity	
Registration No.	011-7S1493 F
Valid until	2022-08-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Page 1 of 1

Certificate	011-7S1493 F dated 2022-01-26
Technical Data	See data sheet, part of the test report of 2016-10-20, 2018-06-27 Note(s): - The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures or with appropriate frost protection controller. - The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.
Testing laboratory/ Inspection body	Universität Stuttgart Institut für Gebäudeenergetik, Thermotechnik und Energiespeicherung Pfaffenwaldring 6 70569 Stuttgart GERMANY
Test report(s)	10COL931, 10COL932, 10COL932Q, 10COL932S dated 2011-04-11 10COL931/2, 10COL932/2, 10COL932Q/2 dated 2016-10-20

